



# City of Chipley



PUBLIC WORKS DEPARTMENT  
671 Rustin Drive  
P.O. Box 1007  
Chipley, Florida 32428  
Phone: (850) 638-6346  
Fax: (850) 638-6314

CITY OF CHIPLEY  
BID NO. 2022-02  
SIDEWALK REPLACEMENT  
ADDENDUM NO. 1

ISSUED: JUNE 9, 2022  
11:00 AM Local Time

1. How much sidewalk will be replaced? **Approximately 312' Linear Feet.**
2. Can you add clarification on the driveway dimension? **The driveway will be approximately 12 feet wide, 12 feet long and will be 6 inches thick.**
3. Is there a bid sheet to put prices on? **Please see attached bid sheet.**
4. Where can I find exhibits A and B? **Please see attached exhibits A and B.**
5. How much curb and gutter needs to be replaced? **Remove curb and gutter from the scope of work, the existing curb and gutter will remain.**